



**TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER RESOURCES
PERMIT FOR CONSTRUCTION OF SUBSURFACE SEWAGE DISPOSAL SYSTEM**

Issued to: [REDACTED] Owner, Developer, Contractor, Installer, Etc. Location: 378 Johnson Hollow rd New Tazewell, TN - County: Union Map/Group: - Parcel: 0 Subdivision: Lot:	Evaluation Based Upon: () 1. Soil Typing by Soil Scientist () a. General () b. High Intensity () c. Extra High Intensity () 2. Soil Percolation Test (x) 3. Environmental Specialist Estimated Absorption Rate: 45 MPI	Type of System: (x) 1. Conventional () 2. Modified Conventional (x) 3. Conventional System Substitute (x) Chamber (x) Expanded Polystyrene (x) Large Diameter Gravelless Pipe Gravel backfill in a 24" wide trench <u>no</u> required? () 4. Low Pressure Pipe () 5. Mound () 6. Lagoon () 7. Subsurface Drip System () 8. Other
Installation: (x) 1. New Installation () 2. Repair to Existing System () 3. System Modification Establishment: (x) 1. Residential: # Bedrooms <u>3</u> () 2. Other: _____ Gal/Day <u>0</u>	Approval Based Upon: State No. T.C.A. 68-221-403 () (c) Percolation Test () (d) Grandfather clause - Current standards except those specified (x) (f) 12" (karst) and 6" (non-karst) buffer required () (i) 9" buffer required (24"-36" total soil depth) () (k) Grandfather clause - meets June 30, 1990 standards (repair only) (x) Current Standards () Other: _____	

Also required:

This system shall consist of a two compartment septic tank holding 900 gallons, with 300 linear feet in 3 trenches, 36 inches wide and 24 (min) to 48 (max) inches deep. (Depth of gravel: 12 inches)

General Comments: Install on contour.
Call 423-494-7339 for final inspection

- () 1. Soil Improvement Practice (SIP)
 - () Curtain Drain
 - () Drawdown Drain
 - () Interceptor Drain
- () 2. Flow Diversion Valve
- () 3. Sewage Pump
 - () Pump Flow Rate (gpm) _____
 - () TDH (ft) _____
- () 4. Other: _____

All installers of subsurface sewage disposal systems must hold a valid annual license from the Tennessee Department of Environment and Conservation.

Please see attached drawing and supporting documentation.

The recipient of this permit agrees to construct or have constructed the above described system in accordance with T.C.A. 68-221-401 et. seq. and The Regulations To Govern Subsurface Sewage Disposal Systems. If any part of the system is covered before inspected and approved, it shall be uncovered by the recipient of the permit at the direction of personnel of the Department of Environment and Conservation. **Any cutting, filling or alterations of the soil conditions on the aforementioned property after this day may render this approval null and void.**

By Gabe Davis, EC1

Date 04/13/2023

(Date of issue)

This is a permit to construct and is not intended to imply approval of any work proposed or completed on this lot.

Tennessee Department of Environment and Conservation - Division of Water Resources
Permit for Construction of a Subsurface Sewage Disposal System



Issued To: [REDACTED]

Location: 378 Johnson Hollow Rd

New Tazewell

[REDACTED]

Inspector: Gabe Davis, EC1

Date: 4/13/23

General Notes:

- Please refer to the design specifications for the subsurface sewage disposal system on the first page of the construction permit.
 - Contact the local Division of Water Resources representative to schedule a final inspection.
 - All electric components (e.g., pump, alarm, etc.) for the subsurface sewage disposal system must be inspected and approved by the appropriate electrical inspector prior to requesting a final inspection. Documentation of the electrical inspection must be available during the final inspection.
- 50' from any well

